

Type test Certificate of Complete Type Test

PT Voksel Electric Tbk

Jakarta, Indonesia

has successfully passed the type test sequence on a

Three-core power cable

Type: 19/33 (36)kV 3x240 mm² CU/XLPE/CTS/HDPE/DSTA/HDPE

The test requirements are stated in clauses 18 and 19 of

IEC 60502-2

The test results are recorded in Certificate No.

08-1055

This Certificate is issued on 12 November 2008

KEMA Nederland B.V.



P.G.A. Bus
KEMA T&D Testing Services
Managing Director

Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.